

TOWN OF BARRE
DEPARTMENT OF PUBLIC WORKS
Water Department
 441 Wheelwright Rd. Barre, MA 01005

PERMIT
W1
 Revised
 03/09/2025

Water Service Connection Application

This permit expires 1 year from date of issue

PERMIT #:

Application Date: _____ **Parcel #:** _____ **Account#:** _____

- No service connection will be made until the applicant has paid the required connection fee.
- No person shall be permitted to connect or cause to be connected, any service pipe for conveying water from any of the main or distributing pipes to any house, building, factory for any purposes whatsoever, without the written permission of the Board of Water Commissioners, nor shall any addition to, or alteration of, any water pipe be made without such written permission.

A. Property Information

Property Owner: _____
 Property Address: _____
 Phone Number: _____ Email: _____
 Mailing Address (if different): _____

B. Contractor Information

Any contractor working on Town of Barre property is required to have a minimum of five hundred thousand dollars (\$500,000) in general liability insurance. This must include comprehensive premises-operations, underground and completed operation hazard. A Certificate of Insurance must be on file with the Water Department.

Company Name: _____ Company Phone: _____
 Company Address: _____
 Person Performing the Work: _____ Phone: _____

C. DOMESTIC SERVICE (1") CONNECTION FEE - \$ 2,000.00

- The applicant shall arrange with a private contractor to :
1. Complete all excavation (minimum five (5) foot depth)
 2. Tap the street main (Road Opening Permit will be required).
 3. Install tapping strap (saddle), corporation stop, tubing, curb stop, curb box to and through the basement of the building.
 4. Any and/or all other requirements set forth by the department.
 5. Applicant shall bear all costs for labor and materials not specifically provided by the department


- The Water Department will provide the following:
1. Water Meter and associated materials (including backflow device)
 2. Installation of the water meter.
 3. Inspection of all completed work before the trench is backfilled.

COMMERCIAL AND INDUSTRIAL SERVICE (over 1")

Services larger than 1 inch will be handled on an individual basis. A meeting with the Water Commissioners, DPW Superintendent and/or the Chief Operator, is required.

Connection Fee Paid: _____ Check #: _____ Date: _____
 Collected By: _____ Certificate of Insurance (\$500,000) Received: _____

PERMIT ISSUE DATE: _____ APPROVAL SIGNATURE _____



TOWN OF BARRE
DEPARTMENT OF PUBLIC WORKS
Water Department
 441 Wheelwright Rd. Barre, MA 01005

PERMIT
W1
 Revised
 03/09/2025
 Page 2

Water Service Connection Application

This permit expires 1 year from date of issue

PERMIT #:

Water Connection Approved Materials List

Single Family Home

- Saddle – double strapped
 - a. Body: Ductile Iron, meeting ASTM A-536
 - b. CC (AWWA)
 - c. 10 mils of fusion applied nylon
 - d. Straps/Bolts, washers – stainless steel type 304 (18-8)
 - e. Gaskets – virgin NBR compounded for water
- The following fittings must be MacDonalds Brass or equivalent (300psi working)
 - a. Tapping Corporation
 - b. Street Curb
 - c. Inside Ball Valve
- All CPPJ connections must have one inch (1”) stainless steel insert
- Service Box – Erie style with plug cover and extension rod
- Plastic Tubing – must be HDPE, 200 psi
- Marking tape – must be one foot (1’) above pipe

Multi-Family Dwelling

- Each unit must have its own connection meeting the requirements as listed above.

Requested Civil Rights Compliance Information

The following information is requested by the Federal Government in order to monitor our compliance with various civil rights laws. You are not required to furnish this information, but are encourage to do so. The law requires that we may not discriminate based upon this information, nor whether you choose to furnish it. However, if you choose not to furnish it, under Federal regulations we are required to note the race and sex on the basis of visual observation or surname. If you do not wish to furnish the above information, please check the box below.

I do not wish to furnish this information _____

Ethnicity:

Hispanic or Latino _____ Not Hispanic or Latino _____

Race/National Origin:

American Indian or Alaskan Native _____ Asian _____

Black or African American _____

Native Hawaiian or Other Pacific Islander _____ White _____


Sex:

Female _____ Male _____

Property Owner Signature: _____ Date: _____

Contractor Signature: _____ Date: _____

Board of Sewer Commissioners: _____



TOWN OF BARRE
DEPARTMENT OF PUBLIC WORKS
Water Department
 441 Wheelwright Rd. Barre, MA 01005

PERMIT
W1
 Revised
 03/09/2025
 Page 3

Water Service Connection PERMIT

This permit expires 1 year from date of issue

h-KU @

ADDRESS: _____

h-KU @ ISSUED _____

PROVIDE THE FOLLOWING INFORMATION FOR THE BUILDING TO BE SERVED.

ACCOUNT #: _____

1. Number of outside faucets: _____
2. Sprinklers (permanent) Lawn: _____ Fire: _____ Area served: _____ sqft.
3. Number of full baths: _____ Number of half baths: _____
4. Number of bedrooms: _____ Number of occupants: _____

Connection Drawing

Connection Inspection

Inspector Name: _____ Signature: _____ Date Inspected: _____

Water Meter Install Date: _____ Water Meter Number: _____ MXU ID: _____



TOWN OF BARRE
DEPARTMENT OF PUBLIC WORKS
Water Department

441 Wheelwright Rd. Barre, MA 01005

PERMIT

W1

Revised
03/09/2025

Part 1	Administration of the Government
Title XXII	Corporations
Chapter 165	Water and Aqueduct Companies
Section 1C:	Plastic pipe connections; installation; notice to property owner or occupant; grounding of structure; penalty

Section 1C. No water company shall install plastic pipe connections in any building or dwelling house without first giving notice to the occupant or owner of said building or dwelling house, and sending a copy of such notice to the wire inspector of the city or town in which the building or dwelling house is located. Such notice shall include a warning that the required grounding of the building or dwelling house might be affected by the installation of plastic pipe. Within thirty days of such notice, the owner of such building or dwelling house shall cause the building or dwelling house to be properly grounded. Upon the expiration of such thirty day period, the wire inspector shall inspect the building or dwelling house to determine that the building or dwelling house has been grounded in accordance with safety standards.

Whoever fails to ground a building or dwelling house in accordance with safety standards within thirty days after such notice, as hereinbefore provided, shall be punished by a fine of not less than fifty nor more than one hundred dollars.

Water Connection Approved Materials List

0 7 =

- Saddle – double strapped
 - a. Body: Ductile Iron, meeting ASTM A-536
 - b. CC (AWWA)
 - c. 10 mils of fusion applied nylon
 - d. Straps/Bolts, washers – stainless steel type 304 (18-8)
 - e. Gaskets – virgin NBR compounded for water
- The following fittings must be MacDonalds Brass or equivalent (300psi working)
 - a. Tapping Corporation
 - b. Street Curb
 - c. Inside Ball Valve
- All CPPJ connections must have one inch (1”) stainless steel insert
- Service Box – Erie style with plug cover and extension rod
- Plastic Tubing – must be HDPE, 200 psi
- Marking tape – must be one foot (1’) above pipe

Multi-Family Dwelling

- Each unit must have its own connection meeting the requirements as listed above.